
NOTE;
CONSTRUCTION SREB:
SREB #1 SHALL BE A HEATED SREB
SREB #2 SHALL BE A HEATED SREB



FLOOR PLAN



## **CODE SYNOPSIS**

2009 IBC AS AMENDED BY ALASKA DEPT. OF PUBLIC SAFETY

OCCUPANCY S-1 PARKING GARAGE (IBC 311.3)

CONSTRUCTION TYPE V-B COMBUSTIBLE WITH NO FIRE RESISTANCE MINIMUM FIRE SEPARATION = 10' CLEAR OR GREATER (IBC 602)

FIRE SEPARATION DISTANCE (702); 10'
BUILDING FACE TO
1) CLOSEST INTERIOR LOT LINE
2) CENTER OF PUBLIC WAY
3) IMAGINARY LINE BETWEEN 2 BUILDINGS = 20'

ACTUAL AREA: 26' x 50' = 1,300 S.F.

S-1 OF V-B ALLOWABLE AREA = 13,500SF (IBC 503) = OK

FIRE SEPARATION NOT REQUIRED FOR FUEL - HEATING EQUIPMENT UNDER 400,000 BTU INPUT (IBC 508.2)

OCCUPANT EXIT LOAD (IBC 1004.1): 1,300SF/200 = 6.5 = SINGLE 36" HINGED EXIT DOOR ok (1015)

FOAM PLASTIC INSULATED WALL & ROOF PANELS SHALL COMPLY WITH IBC 2603 FOR NON-SPRINKLERED BUILDINGS

E PROVIDE TWO EXTINGUISHERS WITH ENCLOSURE CABINETS: DRY CHEMICAL 2-A: 10-B;C MINIMUM WITH ALASKA FIRE MARSHAL - APPROVED SIGNS

## SHEET NOTES

PROVIDE EQUIPMENT UNPACKED, ASSEMBLED AND READY TO USE; LOCATE WHERE DIRECTED BY OWNER

- 1 PORTABLE LADDEF FURNISH ONE PORTABLE ALUMINUM ADJUSTABLE FREE STANDING A-FRAME LADDER 6 TO 11 FOOT A-FRAME HEIGHT RECOMMENDED BY MANUFACTURER FOR INDUSTRIAL HEAVY DUTY 300 POUND RATING. CERTIFIED ANSI A14 COMPILANCE III
- 2 TW0 16" WIDE X 3/4" PLYWOOD SHELVES BETWEEN FRAMING 12" X 12" STEEL SHELF BRACKETS EVENLY SPACED AT 24" O. 55" AND 88" FROM TOP TO FLOOR PAINT SAME AS PLYWOOD WAINSCOT
- SPILL CONTAINMENT CABINET
  14 GAGE STEEL 48" WIDE X 24" DEEP X 78" HIGH WITH 2 PAD LOCKABLE DOORS.
  CENTER PARTITION, COAT ROD, FIXED TOP SHELF, 4 ADJUSTABLE SHELVES.
  YELLOW ENAMEL PAINT FINISH WITH "SPILL CONTAINMENT CABINET" IN 2" HIGH LETTERS.
  WWW.LKGOODWIN.COM MODEL ML248 OR EQUAL
  INSTALL WHERE DIFFECTED
- 2 EACH 5000 LB CAPACITY FLOOR MOUNT SINGLE SIDE CANTILEVER RACK:
  (2) 8' HIGH UPRIGHTS
  (1) BRACE SET BETWEEN UPRIGHTS; 6'
  (10) 24" STRAIGHT ARMS WITH LIPS
  ENAMEL PAINT FINISH
  WWW.LKGOODWIN.COM
  SERIES 1000 OR EQUAL
  INSTALL WHERE DIRECTED
- (2) (2 EACH) CLOSED SHELF UNITS: 18 GAGE STEEL 48" WIDE X 24" DEEP 39" HIGH WITH CLOSED SIDES & BACK (3) INTERMEDIATE ADJUSTABLE SHELVES GRAY ENAMEL, PAINT FINISH WWW.LKGOODWIN.COM IRONMAN OR EQUAL INSTALL WHERE DIRECTED



STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
CENTRAL REGION


HOOPER BAY, AIRPORT
HOOPER BAY, ALASKA
AIRPORT IMPROVEMENTS
PROJECT NO. 59276


Project Engineer Date
Hooper Bay Airport Improvements 57419


AS-BUILT


AIP No. 3-02-0424-006-2014 FLOOR PLAN DATE: 04/04/2015 SHEET: A1 of A5 AS-BUILT SHEET;


3/1/18


























PANEL: C PROJECT: SINGLE BAY LOCATION:	LUGS [] CB (g)	SURF ■ FLSH □	JFEED LGS II SHNT TRP II SBFD LGS II	SUBFEED BKR [] ISO GRND BAR [] SOLID NEUTRAL [8]	
20/240 VOLTS	1 Pi	1 3 WIRE	200 AMP	22,000 (1) AIC	
AUDAL PERSONNETICLE		T WAS NOW	[ 6) 00 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	OF ALLE APPAREMENT	
CIRCUIT DESCRIPTION	KVA	AMP CKT		CIRCUIT DESCRIPTION	
PANEL G	5.83	50/ 1	2 30/1 2.88	NEMA 5-30 RECEPTACLE	
		/2 3	4 30/	SPARE	
50 AMP 240 VOLT NICE	PTACLE 9.6	50/ 5	6 /2	1	
NEMA 6-50R		/2 7	8 30/	SPARE	
NEMA 5-20 RECEPTACLE		20/1 9	10 /2		
NEMA 5-20 RECEPTACLE	S 0.54	20/1 11	12 20/1 0.18	NEMA 5-20 RECEPT C	MPRESSOR
AIR COMPRESSSOR - 3	HP 4.78	50/ 13	14 20/1	SPARE	
		/2 15	16 20/1	SPARE	
SPARE		20/1 17	18 20/1	SPARE	
SPARE		20/1 19	20 20/1	SPARE	
SPACE		21	22 20/1	SPARE	
SPACE		12	24 20/	SPARE	
SPACE		25	72	JEANE.	
SPACE		27	28 20/1	SPARE	
SPACE		29			
	24.53 KVA		30 20/	SPARE	
CONNECTED LOAD:			REMARKS:		
DEMAND LOAD:	24.53 KVA	102.2 A	(1) FAULT CURRE	T BASED ON 50 KVA 1.0%	Z TRANSFORMER
DEMAND + CONT.	25.81 KVA	107.6 A	2. PROVIDE SEPA	RATE NEUTRAL AND EQUIPM	ENT GROUND BARS
DATE:			3. PROVIDE 200/	2 MAIN CB	
REV:					

PANEL: G										
PROJECT: SINGLE BAY SREB			THR	UFEE	D LGS	0	SUBFEED	BKR 🗆		
LOCATION: LUGS II		SURF		SHN	TRP	0	ISO GRND	BAR 🗆		
CB C	3	FLSH		SBFT	LGS		SOLID NEU	JTRAL 🖩		
120/240 VOLTS	1 PH	3	WIRE		100	AMP	22,000	AIC		
							T 5/55/198 58	KANINGAAT		
CIRCUIT DESCRIPTION	KVA		CKT	СКТ	AMP	KVA	CIRCUIT DES	SCRIPTION		
LIGHTING	1.26	20/1	1	2	30/		SPARE			
LIGHTING	0.29	20/1	3	4	/2					
SPARE	1	15/1	5	6	20/		SPARE			
PADDLE FAN & UNIT HEATER	0.75	15/1	7	8	/2					
1/3 HP FUEL PUMP AND DISPENSER	0.83	20/1	9	10	15/1	0.8	DAY TANK PL	JMP		
FUEL PUMP STOP/DISCONNECT	0.1	15/1	11	12	15/1	0.8	DAY TANK PL	IMP		
SPACE			1.3	14	20/1	1.0	LEAK ALARM	PANEL.		
SPACE			15	16			SPACE			
CONNECTED LOAD: 5.83	KVA	24.3	A	REM	ARKS:					
DEMAND LOAD: 5.83	KVA	24.3	A	1. 6	PROVID	E SEPA	RATE NEUTRAL	AND EQUIP	MENT GROU	ND BARS
DEMAND + CONT. 6.47	KVA	26.9	A	2. \	/ERIFY	CB REC	QUIREMENTS FO	OR FUEL DI	SPENSER	
DATE:					-					
REV:										

## NOTES:


(1) PROVIDE MULTIPOLE CIRCUIT BREAKERS OR CIRCUIT BREAKERS WITH HANDLE TIES, AS REQUIRED FOR COMPLIANCE WITH NEC 210.4(B), WHEREVER FIELD WIRING RESULTS IN MULTIWIRE BRANCH CIRCUITS.

LEGEND								
FIXTURE	DESCRIPTION	MOUNTING HEIGHT	LAMP SIZE/ TYPE	E/ REMARKS				
A/150	CELING MOUNT WITH POWER HOX AND SAFET CHAIN, 12,000 LUMENS, MIDE DISTRIBUTION, NO SHELDING, 120 VOLT, 70 CH, 4000K CCT. FIXTURE STROMADE FINISH TO MATCH BUILDING FINISH AS CLOSELT AS POSSIBLE. SUTFABLE FOR "-40", DAMP LOCATION LISTED.  UHHOMA IBL-12L-MO-LP740DLC OR APPROVED EQUAL.	16'-0"	LED					
B/75 💢	WALL MOUNT AREA LIGHT, POLYCARBONATE REFRACTOR, 120-VOLT, 5100K CCT, 5337 LUNENS. PROVIDE NITERAL PHOTO-LECTRIC CELL WHERE NOTED ON PLANS. FIXTURE STANDARD FINESH TO MATCH BUILDING FINESH ST OLSCAPEL AS POSSIBLE. UL LISTED FOR WET LOCATION. HUBBELL PVIJ.3-JOLU-SK-BZ OR APPROVED EQUAL.	2 FEET BELOW ROOF STRUCTURE	LED					
E/60 B	EMERGENCY EGRESS LIGHT, NICKEL-CADMIUM BATTERY, 12V, —40°C RATING, INDUSTRIAL LIGHTING UNIT, UL LISTED FOR WET LOCATION, SURVIVE—ALL SV SERIES CATALOG NO. W=128/1244-2=1_i—D—CW4, OR APPROVED FOLIAI	8'-0"	LE CONTRACTOR DE					
(1)	NOTE SYMBOL - NUMBER INDICATED		1					
\$	SINGLE POLE SWITCH, LIGHTED TOGGLE (LIGHT ON WITH LOAD OFF)	48"						
<b>\$</b> <sub>3</sub>	3-WAY SWITCH, LIGHTED TOGGLE (LIGHT ON WITH LOAD OFF)	18"						
\$т	SINGLE POLE MANUAL MOTOR STARTER SWITCH W/THERMAL OVERLOAD ELEMENT	48"						
\$wp	WEATHERPROOF SWITCH	48"						
\$HOA & SP	DOUBLE POLE HAND-OFF-AUTO SWITCH WITH SPEED CONTROL	48"						
<b></b> ⊕wp	WEATHERPROOF JUNCTION BOX							
E15333	CIRCUIT BREAKER PANEL, SEE PANEL SCHEDULE	6'-6" TO TOP						
	CIRCUIT BREAKER (CB)							
	ELECTRICAL CIRCUIT							
	HOME RUN TO CIRCUIT PANEL WITH PANEL AND BROKKER NUMBER							
*	GROUND ELECTRODE SYSTEM CONNECTION							
<₽	DUPLEX OUTLET, GFCI, NEMA 5-20R	48°						
<b>⊘</b> A	RECEPTACLE, 30 AMP, 120V, NEW 5-30R.	48"		PROVIDE MATCHING ANGLE PLUG				
<b>(A)</b>	RECEPTACLE, 50 AMP, 240V NEMA 6-50R	48"		PROVIDE MATCHING ANGLE PLUG				
D.	DISCONNECT SWITCH, 90A, 2P, S/N, 240V	5'-6"						
Ē,	FAN JUNCTION BOX							
9	MOTOR WIT HORSEPOWER INDICATED							
9	GENERATOR INLET, NEMA L14-30 IN NEMA-3R ENCLOSURE	48"						
UGE	UNDERGROUND ELECTRICAL							
	W VOLTAGE CKT.							
5-SC	RIGID STEEL CONDUIT							
LFMC	LIQUID TIGHT FLEXIBLE METAL CONDUIT							
BCG	BARE COPPER GROUNDING CONDUCTOR							
AFF	ABOVE FINISHED FLOOR		1	A CONTRACTOR OF STATE				

### SREB GENERAL NOTES:

- THE WORK SHOWN ON THIS DRAWING IS APPLICABLE TO SREB #1.
- THE WORK SHOWN ON THIS DRAWING IS APPLICABLE TO SREB #2, EXCEPT FOR THE FOLLOWING:
  - A. PANEL C:
    - PANEL DEMAND + CONT. = 22.99 KVA, 95.8 AMPS @ 120/240V.
  - B. THE FOLLOWING CIRCUIT BREAKERS ARE NOT REQUIRED IN PANEL G (CONVERT THEM TO "SPARE"):
    - 1. LEAK ALARM PANEL (G-14)
    - 2. FUEL PUMP AND DISPENSER (G-9).
    - 3. FUEL PUMP STOP/DISCONNECT (G-11).
    - 4. PART DEMAND + CONT. = 4.29 KVA, 17.9 AMPS @ 120/240V.





STATE OF ALASKA
DEPARTMENT OF TRANSPORTATION
AND PUBLIC FACILITIES
CENTRAL REGION

HOOPER BAY AIRPORT HOOPER BAY, ALASKA SNOW REMOVAL EQUIPMENT BUILDING AIP\_NUMBER: 3-02-0126-006-2014

DATE: 4/3/2015


ELECTRICAL LEGEND AND SCHEDULES

PLAN PREPARED BY MBA CONSULTING ENGINEERS, INC.

DANIEL C						
PANEL: C						
PROJECT: SINGLE BAY SREB		THR	UFEED L	GS 🗆	SUBFEED BKR	
LOCATION: LUGS		SURF	SHNT T	RP 🗆	ISO GRND BAR	
CB B	i	FLSH D	SBFD L	GS 🗖	SOLID NEUTRAL	
120/240 VOLTS	1 PH	3 WIRE	- :	200 AMP	22,000 (1) AIC	
•						
CIRCUIT DESCRIPTION	KVA		CKT A	MP KVA	CIRCUIT DESCRIPTION	
PANEL G	5.83	50/ 1	2 30		NEMA 5-30 RECEPTACE	E
		/2   3	4 30		SPARE	
50 AMP 240 VOLT RECEPTACLE	9.6	50/ 5		/2		
NEMA 6-50R		/2 7	8 30	)/	SPARE	
NEMA 5-20 RECEPTACLES	0.72	20/1 9		/2		
NEMA 5-20 RECEPTACLES	0.54	20/1 11	12 20		NEMA 5-20 RECEPT	COMPRESSOR
AIR COMPRESSSOR - 3 HP	4.78	50/ 13	14 20	/1	SPARE	
		/2 15	16 20	71	SPARE	
SPARE		20/1 17	18 20	71	SPARE	
SPARE		20/1 19	20 20	/1	SPARE	
SPACE		21	22 20	/1	SPARE	
SPACE		23	24 20		SPARE	
SPACE		25		/2		
SPACE		27	28 20		SPARE	
SPACE		29	30 20		SPARE	
CONNECTED LOAD: 24.53	KVA	102.2 A	REMARK	S:	DING	
DEMAND LOAD: 24.53	KVA	102.2 A			T BASED ON 50 KVA 1.0	2 7 TRANSFORMER
DEMAND + CONT. 25.81		107.6 A			RATE NEUTRAL AND EQUI	
DATE:				VIDE 200/		MEIN ONGOID BISTO
DEV:				2007	40	

PANEL: G									
PROJECT: SINGLE BAY SREB			TUD	ICCCI	LGS	п	SUBFEED BKF		
		SURF			TRP		ISO GRND BAF		
LOCATION: LUGS III		FLSH			LGS		SOLID NEUTRA		
				SDIL					
120/240 VOLTS	1 PH	3	WIRE		100	AMP	22,000 A	C	
CIRCUIT DESCRIPTION	KVA		CKT	CKT		KVA	CIRCUIT DESCRI	TION	
LIGHTING	1.26	20/1	1 1	2	30/		SPARE		
LIGHTING	0.29	20/1	3	4	/2				
SPARE		15/1	5	6	20/		SPARE		
PADDLE FAN & UNIT HEATER	0.75	11571	7	B	1/2				
1/3 HP FUEL PUMP AND DISPENSER	0.83	20/1	9	10	15/1	0.8	DAY TANK PUMP		
FUEL PUMP STOP/DISCONNECT	0.1	15/1	11	12	15/1		DAY TANK PUMP		
SPACE			13	14	2071	1.0	LEAK ALARM PAN	EL	
SPACE			15	16			SPACE		
CONNECTED LOAD: 5.83	KVA	24.3	A	REM	ARKS:				
DEMAND LOAD: 5.83	KVA	24.3	Α	1. 6	PROVID	E SEPA	RATE NEUTRAL AND	EQUIPMENT G	ROUND BARS
DEMAND + CONT. 6.47	KVA	26.9	Α	2. \	/ERIFY	CB REC	QUIREMENTS FOR F	UEL DISPENSER	?
DATE:									
REV:									
				_					

(1) PROVIDE MULTIPOLE CIRCUIT BREAKERS OR CIRCUIT BREAKERS WITH HANDLE TIES, AS REQUIRED FOR COMPLIANCE WITH NEC 210.4(B), WHEREVER FIELD WIRING RESULTS IN MULTIWIRE BRANCH CIRCUITS.



LEGEND								
FIXTURE	DESCRIPTION	MOUNTING HEIGHT	LAMP SIZE/ TYPE	REMARKS				
A/150	CELLING MOUNT WITH PROBER HOOK AND SMETT CHAIN, 12,000 LIBERS, WIDE DISTRIBUTION, NO SHELDING, 120 YOUT, 70 CR, 4000K CCT. FIXTURE STANDARD FINISH TO WATCH BUILDING FINISH AS CLOSELY AS PROSIBLE. SUITABLE FOR 440°, DAMP LOCATION LISTED. LITHONIA IB12400-LP740DLC OR APPROVED EQUAL.	16'-0"	LED					
B/75 💢	NALL MOUNT AREA LIGHT, POLYCARBONATE REFRACTOR, 120-VOLT, 5100K CCT, 5337 LUMENS. PROVIDE INVESTME PHOTO-LECTRIC CELL WHERE NOTED ON FLANS. FIXTURE STANDARD FINISH TO MANDE BUILDING FINISH SA CLOSELY AS POSSIBLE. UL LISTED FOR WET LOCATION. HABBELL PIL3-30LU-SK-BZ OR APPROVED EDUAL.	2 FEET BELOW ROOF STRUCTURE	LED					
E/60 B	EMERGENCY EGRESS LIGHT, NICKEL-CADMIUM BATTERY, 12V, -40°C RATING, INDUSTRIAL LIGHTING UNIT, UL LISTED FOR WET LOCATION. SURVIVE-ALL SV SERIES CATALOG NO. W-12SV24N-2-LJ-D-CW4, OR APPROVED EQUAL.	8'-0"	LED					
(1)	NOTE SYMBOL - NUMBER INDICATED							
\$	SINGLE POLE SWITCH, LIGHTED TOGGLE (LIGHT ON WITH LOAD OFF)	48"						
<b>\$</b> 3	3-WAY SWITCH, LIGHTED TOGGLE (LIGHT ON WITH LOAD OFF)	48"						
\$ <sub>T</sub>	SINGLE POLE MANUAL MOTOR STARTER SWITCH W/THERMAL OVERLOAD ELEMENT	48"						
\$ <sub>WP</sub>	WEATHERPROOF SWITCH	48"						
\$HOA & SP		48"						
Ūwp	WEATHERPROOF JUNCTION BOX							
	CIRCUIT BREAKER PANEL, SEE PANEL SCHEDULE	6'-6" TO TOP						
_~_	CIRCUIT BREAKER (CB)							
	ELECTRICAL CIRCUIT							
	HOME RUN TO CIRCUIT PANEL WITH PANEL AND BREAKER NUMBER							
♥	GROUND ELECTRODE SYSTEM CONNECTION							
■ 8	DUPLEX OUTLET, GFCI, NEMA 5-20R	48"						
<b>△</b> A	RECEPTACLE, 30 AMP, 120V, NEMA 5-30R.	48"		PROVIDE MATCHING ANGLE PLUG				
<b>⊕</b> 8	RECEPTACLE, 50 AMP, 240V, NEMA 6-50R	48"		PROVIDE MATCHING ANGLE PLUG				
Ŀ	DISCONNECT SWITCH, 60A, 2P, S/N, 240V	5'-6"						
©,	FAN JUNCTION BOX							
9	MOTOR WITH HORSEPOWER INDICATED							
€.	GENERATOR INLET, NEMA L14-30 IN NEMA-3R ENCLOSURE	48"						
—UGE —	UNDERGROUND ELECTRICAL							
	LOW VOLTAGE CKT.							
RSC	RIGID STEEL CONDUIT							
LFMC	LIQUID TIGHT FLEXIBLE METAL CONDUIT							
BCG	BARE COPPER GROUNDING CONDUCTOR							
AFF	ABOVE FINISHED FLOOR							

# SREB GENERAL NOTES:

- THE WORK SHOWN ON THIS DRAWING IS APPLICABLE TO SREB #1.
- THE WORK SHOWN ON THIS DRAWING IS APPLICABLE TO SREB #2, EXCEPT FOR THE FOLLOWING:
  - A. PANEL C:
    - PANEL DEMAND + CONT. = 22.99 KVA, 95.8 AMPS @ 120/240V.
  - B. THE FOLLOWING CIRCUIT BREAKERS ARE NOT REQUIRED IN PANEL G (CONVERT THEM TO "SPARE"):
    - 1. LEAK ALARM PANEL (G-14)
    - FUEL PUMP AND DISPENSER (G-9).
    - FUEL PUMP STOP/DISCONNECT (G-11).
    - 4. PANEL DEMAND + CONT. = 4.29 KVA, 17.9 AMPS @ 120/240V.







	STATE OF ALASKA
	DEPARTMENT OF TRANSPORTATION AND PUBLIC FACILITIES CENTRAL REGION
LE CONTROL	
REVISION	
	LE CONTROL REVISION


HOOPER BAY AIRPORT HOOPER BAY, ALASKA SNOW REMOVAL EQUIPMENT BUILDING AIP\_NUMBER: 3-02-0126-006-2014


E1 of E4 AS-BUILT SHEET: ELECTRICAL LEGEND AND SCHEDULES


PLAN PREPARED BY MBA CONSULTING ENGINEERS, INC.
















STATE OF A			
DEPARTMENT OF TR			
AND PUBLIC F	1 UNIT HEATER CONTROL	5-24-16	c
CENTRAL R	REVISION	DATE	Y

ALASKA RANSPORTATION **FACILITIES** REGION

HOOPER BAY AIRPORT HOOPER BAY, ALASKA SNOW REMOVAL EQUIPMENT BUILDING AIP\_NUMBER: 3-02-0126-006-2014

Hooper Bay Airport Improvements 57419

HEAT CONTROLS & POWER DETAILS

4/3/2015 E4 of E4 AS-BUILT SHEET